



Temporary Detection

Temporary systems of smoke or heat detectors are frequently utilized during construction to cover an area under construction or demolition. The following are needed to review the temporary system. Contact one of the Boston Fire Department Fire Protection Engineers for more information, 617-343-2188.

- Floor plan with temporary device location.
- Manufacturer Cut-Sheet for devices used.
- “Impairment Letter” describing occupancy, scope of work, and steps taken to provide safe a fire-safe environment.
- Copy of BFD Construction/Demo Permit.
- Copy of BFD Sprinkler Permit, if applicable.